



Ref br.: 11/628/5020

Beograd , 30/03/2011.

SERTIFIKAT O KONTROLISANJU 020311	
Klijent:	„MONTER-EMIT BEOGRAD“, Mitrovdanska br. 25, Beograd
Obim i vrsta kontrolisanja:	Kontrolisanje ispunjenosti uslova izvođača radova za montažu predizolovanog sistema projektno klase „C“, saglasno zahtevima standarda EN 13941:2009.
Predmet kontrolisanja:	Kontrolisanje definisano radnim nalogom 020311 od 02.03.2011.
Izvođač:	„MONTER-EMIT BEOGRAD“, Mitrovdanska br. 25, Beograd
Mesto i datum kontrolisanja:	Beograd, 07.03.2011. do 24.03.2011. god.

Ovim potvrđujemo da smo na osnovu usvojene ponude br. 012/11 INDUSTRY 2 od 22.02.2011. izvršili:

- pregled dokumentacije za montažu predmetnog predizolovanog sistema,
- kontrolu usaglašenosti dokumentacije za montažu predizolovanog sistema sa zahtevima standarda EN 13941 i
- primenu dokumentacije pri montaži predmetnog predizolovanog sistema.

Nakon realizacije predmetnog kontrolisanja utvrđeno je:

1. Specifikacija kontrole kvaliteta usaglašena je sa t.4.5.4 standarda EN 13941
2. preispitivanje projektne dokumentacije sa proverom izbora projektne klase usaglašeno je sa t.4.4 i 4.5 standarda EN 13941
3. Dokumentacija vezana za montažu predizolovanog sistema usaglašena je sa t.7 standarda EN 13941
4. prijemno kontrolisanje elemenata predizolovanog sistema, ostalih materijala i komponenata koji se koriste pri montaži predizolovanog sistema usaglašeno je sa t.5 standarda EN 13941.
5. Aktivnosti transporta i istovara, koja se realizuju putem podugovaranja, usaglašene su sa t.7.2 standarda EN 13941
6. Zavarivački pogon usaglašen je sa t.7.5.2 i t.7.5.3 standarda EN 13941.
7. podugovorena ispitivanja metodama bez razaranja usaglašena su sa zahtevima t.7.5.2.5 standarda EN 13941.
8. Izvođač raspolaže osobljem za koordinaciju zavarivanja, saglasno t.7.5.2.4 standarda EN 13941.
9. Zavarivački kadar usaglašen je sa t.7.5.2.3 standarda EN 13941.
10. Ispitivanje pritiskom i usaglašeno je sa t.7.6 standarda EN 13941.
11. postupak montaže termoskupljajućih spojnica usaglašen je sa zahtevima t.7.7 standarda EN 13941.
12. provera sistema za detekciju usaglašena je sa t.7.10.3 standarda EN 13941
13. Završna dokumentacija usaglašena je sa zahtevima t.7.1, t.7.5.8, t.7.7 i t.7.10.3 standarda EN 13941

**Zaključak:**

Nakon realizovanog predmetnog kontrolisanja utvrđeno je da firma „MONTER-EMIT“ Beograd ispunjava zahteve za izvođača radova na montaži predizolovanog sistema daljinskog grejanja za projektnu klasu „C“, saglasno standardu EN 13941:2009.

Za SGS



**SGS Beograd Ltd.**  
 Bože Jankovića 39  
 11000 Belgrade  
 Serbia  
 t: (381 11) 39 79 833  
 f: (381 11) 39 74 092  
 e: [sgs\\_beograd@sgs.com](mailto:sgs_beograd@sgs.com)

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGSPAPER**  
**09383315**

